



Hiskins Electrical Services

01455 360 370 - 07455 640640
Commercial & Domestic Electricians

Invoice

From:

[Hiskins Electrical Services](#)

Holly Lane, Barwell, Leicestershire, LE9 8BT

Enquiries@HiskinsElectrical.co.uk

Invoice
Number

INV-3181

Invoice Date 21st February 2023

Due Date 21st February 2023

Total Due

£11,277.21

To:

AW Technology David Haigh

West Street, Earl Shilton, LE9 7EJ

DHaigh@AWTechnology.com

EICR Remedial works listed by item number.

1. Supply and installation of adequate containment/support for main earthing conductor from earthing rod.
2. Supply and installation of earthing pit to house earthing rod offering protection and accessibility.
3. Replacement of 4 gang socket at entrance to workshop.
4. Replacement of damaged socket to rear of workshop on wall outside kitchen.
5. Replacement of Luminaire in workshop kitchen is missing diffuser, electrical connections are exposed.
6. Replacement of Junction box in workshop.
7. Premises do not have emergency lighting. As part of replacing all lighting throughout the premises, emergency lighting modules will be added to a percentage.
8. DB3 have front cover screws missing. This will be negated by replacement of the DB
9. Supply and installation of fire resistant supports throughout to cables above false ceiling in workshop.
10. Supply and installation of fire resistant supports throughout to cables above false ceiling in office.
11. Supply and installation of adequate support for cables cupboard where DB3 is situated
12. Apply correct identification to conductors in motor housing for electric gates
13. Supply and installation of earthing conductor to armour of SWA cable supplying electric gate.
14. Supply and installation of adequate support/containment of cables in cupboard where immersion heater is situated.

Thanks for choosing [Hiskins Electrical Services](#) | Commercial & Domestic Electricians
Please Note Hiskins Electrical Services is not a VAT registered business and as such you will
not be charged extra for VAT



15. Addressing of 2 methods of connecting installation to earth.
16. Incoming connection to DB2 is not correctly terminated (Armour on show) This will be negated by installation of replacement DB.
- 17 Main switches are not able to be locked in open position. This will be negated by installation of replacement DB.
18. Switches for maintenance of equipment not cable of being locked in the off position. This will be negated by installation of replacement DB.
19. Labelling of switches provided for maintenance.
20. Supplementary bonding not present. This will be negated by installation of replacement DB.
21. No presence of RCD for fault protection. This will be negated by installation of replacement DB.
22. No presence of RCD for protection against fire. This will be negated by installation of replacement DB.
23. No presence of RCD for socket that may reasonably be used to provide power outdoors. This will be negated by installation of replacement DB.
24. No labelling of circuits present. No diagrams/charts/schedules/etc. This will be negated by installation of replacement DB.

Other works requested.

Supply and Installation of 2 fish switches (1 per floor) for the testing of emergency lighting.

Supply and installation of new circuits to power emergency lighting and required testing switches

Supply and installation of emergency exit luminaires as required at all exits and fire escapes both inside and out.

Replacement of false ceiling panel luminaires throughout - 2 in kitchen area at rear of workshop (1 emergency) - 18 throughout workshop (8 emergency) - 2 in small room to right in middle of workshop (1 emergency) - 18 in 1st floor office (8 emergency) - installation of emergency bulkhead to archive room (this can be removed of this room is removed prior to work commencing.


Supply and installation of emergency batten luminaire to cupboard at front of workshop.

Supply and installation of emergency batten luminaire to downstairs ladies toilet.

Supply and installation of emergency batten luminaire to upstairs ladies toilet.

Supply and installation of emergency batten luminaire to upstairs men's toilet.

Thanks for choosing [Hiskins Electrical Services](#) | Commercial & Domestic Electricians
Please Note Hiskins Electrical Services is not a VAT registered business and as such you will not be charged extra for VAT



Hiskins Electrical Services

01455 360 370 - 07455 640640
Commercial & Domestic Electricians

Invoice

Supply and installation of emergency bulkhead to area outside downstairs toilets.

Supply and installation of emergency bulkhead to area outside upstairs toilets.

Supply and installation of emergency batten to reception area.

Supply and installation of 2 emergency batten to stairs area.

Supply and installation of wiring and accessories to alter existing circuit to accommodate 2 new double metal clad sockets to machine room at rear of workshop

Supply and installation of new circuit to supply one, 16A commando socket to rear right of workshop.


Supply and installation of new circuit to supply one, 16A commando socket to front left of workshop.

Supply and installation of new circuit to supply one, 16A commando socket to front right of workshop.

Supply and installation of new circuit to supply one, 32A commando socket to front right of workshop.

Hrs/Qty	Service	Rate/Price	Adjust	Sub Total
1	Materials and Labour Cost to supply required materials and labour to install them as detailed above.	£22,234.42	0%	£22,234.42
1	Additional Materials required	£320.00	0%	£320.00
1	Shared cost of additional Materials required	£-160.00	0.00%	£-160.00
Sub Total				£22,394.42
VAT Not Applicable				£0.00
Paid				-£11,117.21
Total Due				£11,277.21

Thanks for choosing [Hiskins Electrical Services](#) | Commercial & Domestic Electricians
Please Note Hiskins Electrical Services is not a VAT registered business and as such you will not be charged extra for VAT



Hiskins Electrical
Services

01455 360 370 - 07455 640640
Commercial & Domestic Electricians

Invoice

Payment is due upon completion. Late payment is subject to fees of 5% per day. Payment should be made to Account Number 28726012, Sort Code 070806, Account Name Karl Atkins

Thanks for choosing [Hiskins Electrical Services](#) | Commercial & Domestic Electricians
Please Note Hiskins Electrical Services is not a VAT registered business and as such you will
not be charged extra for VAT